



NEW HAVEN PUBLIC SCHOOLS

February 7, 2025

Mr. John Rosa  
CONN-OSHA Director  
38 Wolcott Road  
Wethersfield, CT 06109

Re. Wilbur Cross High School

The New Haven Public Schools (NHPS) acknowledges receipt of the CONN-OSHA letter dated January 9, 2025 in regards to the health hazards at Wilbur Cross High School.

**Leaks, mold, pest, air quality & HVAC concerns**

Location: Throughout the building.

- A walkthrough specific to the noted concerns was performed 1/22/25. At the time of the inspection, no evident deficiencies were observed relative to the 34 locations indicated.
- Documented work history in the time period 9/1/24 to 1/10/25 (date of letter) specific to the categories of Pest, Roof, and HVAC:
  - 3 roofing concerns resolved (Eagle Rivet reports attached)
  - 11 pest concerns resolved
  - 20 HVAC concerns resolved
- From air quality concerns in the Fall of 2024, testing was performed in the following locations:
  - V Wing 1/9/25 - results negative
  - Band Room area 9/4/25 - results led to a detailed cleaning by ServPro; retest on 9/24 - negative results.
  - Library 8/30/24 - results led to a detailed cleaning and replacement of the old carpeting with LVT over winter break (invoice attached); retest on 9/24 - negative results.

If you have additional questions, please feel free to contact Mike Carter in Operations at [mcarter@new-haven.k12.ct.us](mailto:mcarter@new-haven.k12.ct.us) or Jamar Alleyne in Facilities at [Jamar.Alleyne@new-haven.k12.ct.us](mailto:Jamar.Alleyne@new-haven.k12.ct.us).

Best Regards,

Dr. Madeline Negrón  
New Haven Public Schools, Superintendent